



AMERICAN PUBLIC WORKS ASSOCIATION

APWA

New Mexico Chapter

*New Mexico Standard Specifications for
Public Works Construction, 2006 Edition*



EXHIBIT

tabbies

3217-12

PREFACE

This publication of the New Mexico Standard Specifications for Public Works Construction, 2006, supersedes the 1987 Edition of similar title.

These standard specifications may be amended by updates and/or local modifications including: Technical Specifications, standard details, drawings and pre-approved products list. It is the responsibility of the user to amend these standard specifications to make them specifically applicable for their project.

An appendix is included for the user's reference and information. Use of the appendix is not included in the standard specifications unless otherwise noted in the project construction documents.

Future Specifications Committee approved changes or additions to this publication will be furnished holders of these specifications for insertion in their books.

To assist the Specifications Committee in maintaining these specifications in a current condition it is requested that any comments, additions, or corrections be forwarded to the Chairman of the Specifications Committee or current Chapter President, whose names and contact information can be found at:

<http://newmexico.apwa.net>

or

NMAPWA

Specification Committee

PO Box 15996

Rio Rancho, NM 87174-0996

SECTION 301

SUBGRADE PREPARATION

301 GENERAL

301.1 The work performed under this specification shall include, but not be limited to providing the equipment, labor and materials for the preparation of soil subgrade and maintenance of the prepared subgrade for the construction of graded aggregate base, asphalt treated base, cement treated base, asphalt concrete, Portland cement concrete, sidewalks, curb and gutter, drive pads, valley gutter, median pavements and/or any other roadway improvements.

301.2 REFERENCES

301.2.1 ASTM:

C136	D423
D424	D698
D1140	D1557
D2844	D2922
D3017	

301.2.2 This publication

Section 204

301.3 MATERIAL

301.3.1 Subgrade material may be on site soil, combinations of pulverized asphalt concrete and soil, and/or pulverized Portland cement concrete and soil, imported soils, complying with the requirements of this specification. Flowing, sugar sands shall not be used for subgrade material.

301.3.2 All soft and unstable material and other portions of the subgrade which will not compact readily or serve the intended purposes shall be removed and replaced with suitable material from excavation or borrow or suitable materials shall be added and, by manipulations, be incorporated into the subgrade to produce a material meeting subgrade requirements.

301.3.3 All subgrade material shall have a minimum Resistance Value (R-Value), as determined by ASTM D-2844, equal to or greater than the design R-Value for the pavement section. If the subgrade soils encountered during construction have a R-Value less than the design R-Value, those subgrade materials shall be removed to a depth of not less than two (2') feet below the finished subgrade elevation or as authorized by the ENGINEER and to the horizontal limits authorized by the ENGINEER, and replaced with subgrade material having an R-

Value greater than the design R-Value. On small projects, in areas that just involve replacement of existing roadway items or when no design R-Value has been established this R-Value requirement may be waived if authorized by the ENGINEER.

301.4 SUBGRADE COMPACTION

301.4.1 Subgrade preparation shall extend to one foot (1') beyond the limits of the improvement to be placed on the subgrade except when that improvement abuts an existing structure and/or the limits of the right of way. Where an improvement abuts an existing structure and/or the limits of right of way, the subgrade preparation shall extend to the edge of the existing structure and/or the limits of right of way, as specified in the plans, specifications, supplemental technical specifications or as directed by the ENGINEER. Where existing structures are in the right of way or construction easements, subgrade preparation shall extend to the face of the structure, as specified above. Subgrade preparation shall not extend below the bottom of the foundation of an existing structure without specific authorization by the ENGINEER.

301.4.1.1 Subgrade preparation for roadway improvements shall be performed after completion of earthwork construction, subsurface utility installation and trenching back fill within the limits specified, as directed by the ENGINEER. The subgrade preparation shall extend the full width of the roadway to either one (1) foot back of new curb and gutter, and/or to the face of existing structures, and/or the limits of right of way, as specified in the plans and specifications, as directed by the ENGINEER.

301.4.1.2 Subgrade preparation for sidewalks and drive pads shall extend a minimum of one (1') beyond the free edge of the improvement, and/or to the limits of right of way, and/or to the face of existing structures.

301.4.1.3 The subgrade preparation for roadway construction without curb and gutter, shall extend one (1') beyond the edge of the pavement, and/or to the face of existing structures, and/or to the limits of right of way, as specified in the plans and specifications, as authorized by the ENGINEER.

301.4.1.4 Subgrade preparation shall extend the full width of roadway medians four (4) feet wide or less. In areas that the medians are wider than four feet (4') the subgrade compaction shall extend one foot

(1') beyond the median edge of the pavement or back of the median curb.

301.4.2. The subgrade for arterial/collector roadway shall be ripped to a minimum depth of one (1) foot, brought to uniform moisture content, and compacted to the requirements of plans and specification, as authorized by the ENGINEER. Subgrade material with either 20 per cent or more material passing a no. 200 sieve shall be uniformly mixed and moisture conditioned using a tractor mounted mixer or disced after ripping, as specified in the plans and specifications, as authorized by the ENGINEER. The subgrade for reconstructed curb and gutter, sidewalks, drive pads, residential roadways, bicycle paths and other roadways shall be scarified to a minimum depth of six (6) inches, brought to uniform compaction moisture content, and compacted to the requirements of plans and specification, as authorized by the ENGINEER.

301.4.3 Subgrade area shall be compacted to a dry density greater than 95 per cent of maximum dry density in a moisture range of optimum moisture \pm 2% as determined in accordance with ASTM D1557, unless the material contains 35% or more material finer than the No.200 sieve. If the subgrade material has 35% or more material finer than the No.200 sieve, the subgrade shall be compacted to a dry density greater than 95 percent of maximum dry density in a moisture content range of at least optimum moisture to optimum moisture +4%, as determined in accordance with ASTM D698.

301.4.4 Areas on which roadway pavement items are to be placed shall be compacted uniformly to the required subgrade density at the same time. Obtaining the required subgrade density in trench areas at a different time than obtaining the required subgrade density in the adjacent pavement areas will not be permitted.

301.4.5 Upon completion of the subgrade preparation, the CONTRACTOR shall maintain the compacted subgrade density and moisture content at the specified levels until the next lift of material is completed. The CONTRACTOR shall provide continuous moisture protection of the subgrade by either sprinkling or the application of a prime coat, as directed by the ENGINEER.

301.5 SUBGRADE TOLERANCES

Subgrade upon which pavement, sidewalk, curb and gutter, drive pads, or other structures are to be placed shall not vary more than $\pm 1/4$ inch or $\pm 1/2$ inch per 10 foot in any direction from the specified grade and cross section. Subgrade upon which base material is to be placed shall not vary more than $\pm 1/2$ inch or ± 1 inch per 20 foot in any direction from the specified grade and cross section. Variations within the above specified tolerances shall be compensating so that the average grade and cross section specified are met.

301.6 TESTING:

301.6.1 A sample of each type of soil encountered shall be classified in accordance with the requirements of ASTM D2487, the moisture density relationship determined in accordance either ASTM D698 or D1557, whichever is applicable and an estimated resistance R-value assigned based on plasticity index, PI, and percent material passing No.200 sieve.

301.6.2 Compaction tests shall be taken for each 500 sy or less, as directed by the ENGINEER. Compaction tests shall be taken in accordance with ASTM D2922 and D3017. Areas represented by non complying tests shall be reworked as specified, and retested for compliance.

301.6.3 Test reports shall include but not be limited to the requirements of TABLE 301.A.

TABLE 301.A
TEST REPORT INFORMATION

A. Field Data

Date of Sampling/Field Test

Project Number or

Permit Number

Project Title

Location of sample/field test as defined by the project plans and specifications

Time of Sampling/field testing

Field test results with reference specification limits

B. Laboratory Data

Soil classification

Soil gradation

Plasticity index

Liquid limit

Optimum moisture/maximum dry density relationship and graph

Estimated soil resistance R-Value

301.6.4 Test results shall be reported to the ENGINEER and CONTRACTOR in writing, within 4 working days of completion of the sampling and or field test. Non-complying test shall be reported within 1 working day of completion of the test.

301.7 MEASUREMENT AND PAYMENT:

301.7.1 Measurement for payment of roadway subgrade preparation will be by the square yard to the limits of the surfacing, as authorized by the ENGINEER. Payment for subgrade preparation shall include all labor and equipment required to shape, mix, add moisture, compact, bring to grade and maintaining the prepared subgrade moisture and density until the next course of material is placed.

301.7.2 The measurement of payment for subgrade preparation for non-pavement roadway items such as curb and gutter, valley gutter, drive pads and sidewalks etc., shall be included in that item. No separate payment will be made.